

ELECTRICITY DISTRIBUTION
COMPANY (EDCO)
AMMAN - JORDAN
REF. : 1/2024/5940
DATE : 17/04/2024



شركة توزيع الكهرباء المساهمة العامة
(عمان - الأردن)
الرقم :
التاريخ :

TELEFAX MESSAGE

TO	COMPANY :	
	ATTENTION :	
	FAX NO. :	
	COUNTRY :	

SUBJECT : Tender No.(22/2024):Supplying of smart meters with HES – Clarifications#2

Dear Sir,

Related to the tender No. (22/2024) for supplying smart meters with HES.
Kindly be informed the attached clarifications and EDCO reply for tenderer questions.

Best Regards,

Director General
Eng Reem Hamdan

CC	
From	

فاكس : (+962-6) 5341213 / (+962-6) 5331330 / 830878 عمان 11183-الأردن.
FAX : (+962-6) 5341213 / (+962-6) 5331330 / 830878 AMMAN 11183 JORDAN



No.	Questions	EDCO Reply
1	What does these two meters models (DDSY283SR, DTSD545) means? Can you give morer details?	This optional item related to EDCO installed meters produced in 2017 and provided from chinese manufacture "Holley"
2	Should offered meter need to pass all threes HES validation test? If no, how will we know which HES need to be validated to obtain certificates and license? Any chance if meter move from one of HES to another after validation test?	Meters' Firmware and communication modules shall be successfully capable to integrate with one of EDCO excisting HES as specified, or the new HES (to be supplied in this tender) as specified in HES specifications. A certified document proving tenderer offered meters had operated successfully with one of Head End is enough
3	If existing HES claims requires more hardware to connects new meters in this tender, is this responsibility of EDCO? If we provides our HES will EDCO provides needed hardware. DB and OS?	Please obligate with EDCO HES specification point No (3) for the existing EDCO HES. If you provide a new HES it is tenderer responsibility to provide the needed hardware, DB and OS in their offer.
4	What if "0.4% Exstockspareparts (meters+modems) is used up? Doest EDCO will purchase new meters to fulfill the stock?	This quantity will request only in case needed for rush replacement for the defective meters
5	Could you explain what voltage application below clouse? voltage application should appear in date wise at meters load profile.	Load profile & Events should be accepted to store voltage status