

ELECTRICITY DISTRIBUTION
COMPANY (EDCO)
AMMAN - JORDAN
REF. : 1/2024/6792
DATE : 30/04/2024



شركة توزيع الكهرباء المساهمة العامة
(عمان - الأردن)
الرقم :
التاريخ :

TELEFAX MESSAGE

TO	COMPANY :	
	ATTENTION :	
	FAX NO. :	
	COUNTRY :	

SUBJECT : Tender 20/2024 supply of cable joint and terminations -clarafications

Dear sir

Reference to the tender No. 20/2024 supply of cable joint and terminations, kindly be informed EDCO replies and clarifications to tenderers questions as per the following table:

#	Question	EDCO clarifications & replies to tender 20/2024
1	Item#1: is transition joint for XLPE to PILC cable? Or straight joint only for XLPE or PILC cable?	The required joint, will be used for maintenance purposes; connected the old cables that has paper insulation with new one that has XLPE insulation
2	Item# 29. - Tape lead for iron joints (about 5 meters per unit) (Kindly advise or clarify what is iron joints and required tape lead)?	The required is an insulation tape used with M.V terminations and joints
3	The requested training certificates are for attendance or certifications	The required certificates are for attendance

This is for your information and your ready reference in regards.

Yours Faithfully

Director General

Eng Reem Hamdan

CC	
From	

فاكس : (+962-6) 5341213 / (+962-6) 5331330 / عمان 11183- الأردن.
FAX : (+962-6) 5341213 / (+962-6) 5331330 / AMMAN 11183 JORDAN

