

TECHNICAL SPECIFICATIONS

1. GENERAL

Materials included in this tender are for use in electricity distribution networks including (33, 11 & 0.4) kV overhead lines and associated substations.

Tenderer must insure that materials are of the best quality and confirm to the latest IEC standards.

2. Copper Cable Lugs and straight Ferrule

The required copper cable lugs shall be suitable for connecting the specified copper cables with copper bus-bar. Copper Cable Lugs and straight Ferrule Must be of compression type and shall comply with DIN 46235 or equivalent and the current carrying capacity for lugs shall be suitable with the current carrying capacity for cables as specified in IEC 60287.

Cu cable lugs size 16 mm² will be used for 16mm² cables with KWH meters so the diameter of screw shall be 8mm.

3. Bimetallic Cable Lugs

The required Bimetallic (Copper-Aluminum) cable lugs shall be suitable for connecting the specified aluminum cables with copper bus-bars. They must be of compression type and shall comply with DIN 46235 or equivalent, and the current carrying capacity for lugs shall be suitable with the current carrying capacity for cables as specified in IEC 60287.

4. TESTS:

The cable lugs shall be tested in accordance to IEC 61238-1, tenderer shall prove the required parameters laid down in the specifications, guaranteed schedules and bidder's offer. Detailed test certificates shall be submitted to EDCO.

5. REFERENCES:

Bidder must include with his offer a detailed reference list indicating types, quantities, and years of service of the same offer items he supplied as well as detailed address of buyers, particularly these buyers having same climatic conditions in the region.

6. OFFER CATALOGUES AND SAMPLES:

Each offer should be attached with catalogues with a clear drawing with dimensions and other technical specifications for each type of the offer items.

A sample of each type should be submitted with the offer and any offer received without drawings and samples will be rejected during evaluation without any prior notice.

SCHEDULES AND GUARANTEES

<u>SCHEDULE NO.</u>	<u>DESCRIPTION</u>
A	Schedule of Requirements
B	Price schedules
C	Guaranteed delivery period schedules
D	Manufacturers, places of manufacture and testing place
E	List of test certificates
F	Reference list
G	Deviation from specifications Schedules if any

SCHEDULE (A1)

SCHEDULE OF REQUIREMENTS

Item No.	Description	Stock Code	Unit Item	Quantity Required
1.	Copper cable lugs for Cu cables with the following sizes:- a-10 mm²		No.	1000
2.	Bimetallic cable lugs suitable for the following size cable: a-70mm² b-240mm²		No. No.	70 350

SCHEDULE (B1)
PRICES SCHEDULES

ITEM NO.	DESCRIPTION	QTY AND UNIT	UNIT PRICE & CURRENCY		TOTAL PRICE C &F AQABA JORDAN
			FOB	C &F AQABA	
1.	Copper cable lugs for Cu cables with the following sizes:- a-10 mm ²	1000			
2.	Bimetallic cable lugs suitable for the following size cable: a-70mm ² b-240mm ²	70 350			
TOTAL PRICE (C & F) AQABA					

IMPORTANT NOTES:

1-EDCO HAS THE RIGHT TO ACCEPT PARTIAL OFFERS AND TO AWARD PART OF THE ITEMS OR QUANTITIES WITHOUT ANY LIMIT REGARDLESS CLAUSE (2.3) FROM SECTION III (GENERAL CONDITIONS OF CONTRACT).

2- EDCO HAS THE RIGHT TO REJECT ANY OFFER BASED ON EDCO EVALUATION TO THE QUALITY, RELIABILITY AND WELL-KNOWN MANUFACTURERS.

SCHEDULE (C1)

GUARANTEED DELIVERY PERIODS IN WEEKS

DESCRIPTION	DELIVERY PERIOD FOB-SPECIFY PORT	DELIVERY PERIOD AQABA PORT JORDAN
Copper cable lugs for Cu cables with the following sizes:- a-10 mm ² Bimetallic cable lugs suitable for the following size cable: a-70mm ² b-240mm ²		

Delivery period shall be as short as possible, and it will be considered during evaluation, at any way the delivery time shall not exceed (8) weeks, C&F Aqaba port from the date of receipt EDCO purchasing order.

SCHEDULE (D1)
MANUFACTURERS, PLACES OF MANUFACTURE AND TESTING
PLACE

DESCRIPTION	MANUFACTURER	PLACE OF MANUFACTURE	PLACE OF TESTING
<p>Copper cable lugs for Cu cables with the following sizes:-</p> <p>a-10 mm²</p> <p>Bimetallic cable lugs suitable for the following size cable:</p> <p>a-70mm²</p> <p>b-240mm²</p>			

SCHEDULE (E1)

LIST OF TEST CERTIFICATES FOR TESTED EQUIPMENT

Tenderers shall provide the information required below for the type test certificates from a recognized testing station covering the equipment offered to BS or IEC recommendations & shall be submitted with the tender.

Failure to provide copies of type test certificates/reports could result in rejection of the tender.

Type test made on identical designs of equipment to those offered	Certificate No.	Certificate Authority

SCHEDULE (F1)

SERVICE EXPERIENCE OF FOR OFFERED MATERIALS

Tenderers shall provide the information required below for the service experience of the same offered materials.

Customer	Description	Total Quantity (Pc.)	No. of years in service

SCHEDULE (G1)

DEVIATIONS FROM SPECIFICATIONS (IF ANY)
TO BE COMPLETED BY THE TENDERER

ITEM NO.	BREIF DESCRIPTION	DEVIATIONS